

# MERRELL BROS.

Cass County  
IN 0050971

## A Biosolids Management Corporation

- Liquid / Dry Land Application
- Land Permitting
- Digester and Lagoon Cleaning
- State / Federal Reporting
- Consulting Services
- Off-Site Biosolids Storage
- Dredging
- Belt Pressing
- Marketing and Distribution Programs


CC: Lynn Raiser  
Gary Starks  
Don Daily  
Deb Dubenetzky

## CERTIFICATE OF DISPOSAL

THIS LETTER CERTIFIES THAT ON:

5/15/07

16,665 GALLONS OF BIOSOLIDS WERE TRANSPORTED FROM THE **MAPLE LANE VILLAGE TREATMENT PLANT** INTO THE MERRELL BROS. REGIONAL BIOSOLIDS CENTER. SAID BIOSOLIDS WILL BE DISPOSED OF BY LAND APPLICATION UNDER MERRELL BROS. LAND APPLICATION PERMIT #INLA 000590. THIS LETTER SERVES AS PROOF OF DISPOSAL FOR THE ABOVE MENTIONED FACILITY.



**MERRELL BROS., INC.**  
**REGIONAL BIOSOLIDS CENTER**



INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT  
*We make Indiana a cleaner, healthier place to live.*

Mitchell E. Daniels, Jr.  
Governor

Thomas W. Easterly  
Commissioner

May 11, 2007

100 North Senate Avenue  
Indianapolis, Indiana 46204  
(317) 232-8603  
(800) 451-6027  
www.IN.gov/idem

**VIA CERTIFIED MAIL** 7002 0510 0003 8209 3507

Mr. Robert Pryber, Manager  
Anoka MHP, Inc.  
1120 North Main Street  
Rochester, Michigan 48307

Re: **Inspection Summary Letter**  
Maplelane MHP Wastewater Treatment Facility  
NPDES Permit No. IN0050971  
Logansport, Cass County

Dear Mr. Pryber:

On March 27, 2007, a representative of the Indiana Department of Environmental Management, Office of Water Quality, conducted an inspection of the Maplelane MHP wastewater treatment facility, located at 2808 South U.S. 35, Logansport, Indiana. This inspection was conducted pursuant to IC 13-14-2-2. For your information, and in accordance with IC 13-14-5, a summary of the inspection is provided below:

Type of Inspection:   X   Reconnaissance Inspection

Results of Inspection:        No violations were observed.  
       Additional information/review is required to evaluate overall compliance.  
  X   Potential problems were discovered or observed.

The following concerns were identified:


1. Part II. B. 1 of the permit states, in part, that all waste collection, control, treatment, and disposal facilities shall be operated as efficiently as possible and in a manner which will minimize upsets and discharges of excessive pollutants. This includes the facility's solids handling program.

At the time of the inspection, the facility's sludge digester was full and in need of cleaning.

2. The Effluent Limits Violations portion of the NPDES Facility Notice of Inspection was rated as marginal due to ammonia violations in March and April 2006.

Within thirty (30) days of receipt of this letter, a written detailed explanation, documenting compliance with Item 1 listed above, must be submitted to this office. Failure to respond adequately to this Inspection Summary Letter may result in a referral to IDEM's Office of Enforcement. Please direct any response to this letter and any questions to Lynn Raisor at (317) 233-2488 or by cell phone at (317) 691-0099. Thank you for your attention to this matter.

Sincerely,

  
Donald R. Daily, Inspection Section Chief  
Compliance Branch  
Office of Water Quality

**INDIANA-OHIO WATER TREATMENT, INC.**

4848 W. Division Rd. Huntington, IN 46750

Phone/FAX 260-468-2546

# Fax

<b>To:</b> Lynn Raisor	<b>From:</b> Ernest W. Booth Jr.
<b>Fax:</b> (317) 232-8697	<b>Pages:</b> 3
<b>Phone:</b> (317) 233-2488	<b>Date:</b> 6/12/2007
<b>Re:</b> Maple Lane MHP NPDES Permit No IN0050971 Logansport, Cass County	<b>CC:</b> Robert Pryber Anoka MHP, Inc Rochester, MI 48307
<input type="checkbox"/> Urgent <input checked="" type="checkbox"/> For Review <input type="checkbox"/> Please Comment <b>Please Reply</b> <input type="checkbox"/> Please Recycle	

Attention: Lynn Raisor

In respond to your Inspection Summary Letter , dated May 11, 2007 on your inspection of Maple Lane MHP, the following actions have been taken:

1. Adjustments were made to plant operation to correct the ammonia problem. (Corrections were made at the time the ammonia violations were detected)
2. The land application permit has been renewed. (Certifying letter from Merrell Bros. is included.) Excessive sludge from digester & lagoon were removed

If you have any questions please call:

Ernest W. Booth Jr. @ 260-519-1427